



City of Manistee
70 Maple Street
Manistee, MI 49660

SAFEbuilt, Inc.
107 S. Capital Avenue
P.O. Box 190
Athens, MI 49011
Office: 269-729-9244
Fax: 269-729-9254
Email: athensmi@safebuilt.com

Note: This checklist may be used as a guide for property compliance with the City's Property Maintenance Code. The list contains commonly found violations. It is not a comprehensive list of all violations that could be identified. If you have a question about a specific situation, please contact SAFEbuilt at 269-729-9244.

Generally: The property premises, exterior of every structure, interior of every structure, and the systems and equipment therein shall be maintained in good repair, structurally sound, and in sanitary condition so as not to pose a threat to health, safety, or welfare of occupants. All appliances shall be capable of performing their intended function.

EXTERIOR

- Address numbers for each unit visible from the road and at least 3" high.
- Chimney in good condition (no rust or loose bricks)
- Doors weatherproof and deadbolt lockable, all hardware operable
- Screen/storm doors in good condition, no broken/missing glass or torn/missing screens, all hardware intact and operable
- Driveway and sidewalk in good condition, free of trip hazards and standing water
- No driving/parking occurring on unpaved surfaces (lawn/yard areas)
- Foundation structurally sound and weatherproof, no open cracks or breaks
- Garage, shed and/or fences structurally sound, waterproof, and in good condition
- Handrails/guardrails sturdy weatherproof, at least 30" high, spindles less than 4" apart
- Openings sealed to prevent the entry of rodents or animals
- Property graded so that water does not accumulate
- Roofs, shingles, eaves, soffits, and fascia in good repair (painted, weatherproof, not rotted)
- No rubbish or debris on property (except within a trash container)
- Siding, trim, and paint in good condition (not missing, peeling, or chipped)
- Steps, decks, porches, and landings weatherproof in good/safe condition
- No unlicensed or inoperable vehicles parked outside a garage
- All yard growth maintained at less than 6" high (exception: typical landscaping)

SMOKE DETECTORS

- Smoke detectors must be installed inside and outside of each sleeping area. One on every level is required, including the basement. Hard wiring with battery backup is the preferred method of installation. An electrical permit may be required.

BASEMENT

- Stairs structurally sound, no trip hazards, handrail in place that extends entire length of stairs. No opening greater than 4"
- An open side of stairs must have a guardrail at least 30" high with spindles less than 4" apart
- Water heater must have a pressure relief valve, drip leg, to within 4" of the floor, and be properly vented
- Dryer correctly vented to the outside using only metallic duct material (no vinyl)
- Washer properly hooked-up and properly drained
- No combustible items stored within 3' of furnace or any heating appliance

INTERIOR

- At least 50 square feet of bedroom area per occupant (including infants and children), 70 square feet minimum for a one-person bedroom
- Bathrooms must have a window that opens or working vent fan
- Seven (7) feet minimum ceiling height in all rooms
- Floor coverings clean, in good condition, and free from trip hazards (no ripped/torn carpet)
- Heat supplied to maintain all habitable rooms at a minimum of 68° F
- All mechanical equipment and systems functioning as designed
- All rooms must be a minimum of 7 feet x 7 feet; kitchens must have a clear passageway not less than 3 feet wide
- All sleeping rooms must have proper egress
- All surfaces properly maintained including woodwork/trim, counters, cabinets, etc.
- Unit is clean, sanitary, and free from rodent or insect infestations
- Walls and ceilings free from holes, cracks, flaking/peeling paint, and loose plaster

ELECTRICAL

- All cover plates for outlets, switches, and junction boxes in place
- GFI outlets installed in bathroom, laundry room, and kitchen
- Each habitable room must have a minimum of 2 outlets which are remote from one another

PLUMBING

- All drains work properly (not slow or plugged) and must hold water
- All fixtures in good repair, not rusted or corroded, and operable as designed
- Hot and cold water available, adequate water pressure
- No leaks in plumbing or dripping faucets
- Toilets flush completely and do not run

WINDOWS

- All windows must be operable, hardware must work properly and hold the window in an open position
- All windows must have locking hardware that works properly
- Window sashes, sills, and frames in good condition and neatly painted
- Windows weatherproof, not broken or cracked
- Windows 24" or less above floor needs removable min. 12" high guard

REQUIRED PERMITS

Permits are required for many projects including new construction, some remodeling, garages, decks, porches, siding, roofing, Mechanical work, Electrical work and new Plumbing fixtures and work. Other permits that may be required are for fences, driveways, and land use.

Building, Electrical, Plumbing, and Mechanical permits are issued by Safebuilt Inc. Applications are available online at cornerstonemi.net.